


YP69 Straight male union connector.

Straight male union connector. copper x BSP taper male thread. Cone joint to BS 1010.







DIMENSIONS (mm)

GENERAL INFORMATION

Code	Description	а	Za	s
08810	8mm x 1/4" YP69	38	18	21
08812	12mm x 3/8" YP69	47	35	24
08813	15mm x 1/2" YP69	61	46	31
08814	22mm x 3/4" YP69	70	48	37
08816	28mm x 1" YP69	77	54	46
08817	35mm x 1 1/4" YP69	73	46	53
08818	42mm x 1 1/2" YP69	86	55	65
08819	54mm x 2" YP69	107	70	82

PRESSURE & TEMPERATURE

YORKSHIRE POTABLE PERFORMANCE WHEN CORRECTLY ASSEMBLED WITH COPPER TUBE TO BS EN

Service temperature

Size	-40°C (Min)	30°C	65°C	110°C (Max)
6mm to 54mm	16 bar	16 bar	10 bar	6 bar
67mm	10 bar	10 bar	6 bar	4 bar

Pegler Yorkshire 25 Year Guarantee - Terms and Conditions

Products are subject to a 25 year guarantee that is between Pegler Yorkshire and the final purchaser of the

The guarantee is subject to proof of purchase being supplied.

This guarantee does not affect any statutory rights the consumer may have in law.

The guarantee covers manufacturing or material defects when installed in accordance with our instructions on specified tube materials and applications, and does not cover parts subject to normal wear and tear.

This product range has been designed for the use of homeowners, domestic and commercial applications and therefore the Guarantee is subject to the product being properly selected for their intended service conditions.

The guarantee is not applicable where the product is fitted contrary to the conditions in the fitting instructions.

This is reinforced where valves are covered by the European Pressure Equipment Directive (PED97/23/EC) where Installation, Operating and Maintenance Instructions are supplied with each product and/or carton.

Provided it is installed correctly and receives adequate preventative maintenance it should give years of trouble-

Abusive behaviour and accidental damage to the product are not covered by this guarantee.

The extent of this liability is limited to the cost of the replacement of the defective item and not to installation or consequential damages.

APPROVALS





BSI

WRAS

