


YP72 Female nipple.







Female nipple. union thread x BSP parallel female thread. Cone joint to BS 1010.



DIMENSIONS (mm)

Code	Description	а	S
08891	1/2" X 3/8" YP72	25	21
08892	3/4" X 1/2" YP72	31	28
08893	1" x 3/4" YP72	33	34
08894	1 1/4" x 1" YP72	36	44
08895	1 1/2" x 1 1/4" YP72	43	50
08896	2" x 1 1/2" YP72	45	62
08897	2 1/2" x 2" YP72	48	77

PRESSURE & TEMPERATURE

YORKSHIRE POTABLE PERFORMANCE WHEN CORRECTLY ASSEMBLED WITH COPPER TUBE TO BS EN 1057

Service temperature

Size	-40°C (Min)	30°C	65°C	110°C (Max)
6mm to 54mm	16 bar	16 bar	10 bar	6 bar
67mm	10 bar	10 bar	6 bar	4 bar

GUARANTEE

Pegler Yorkshire 25 Year Guarantee - Terms and Conditions

Products are subject to a 25 year guarantee that is between Pegler Yorkshire and the final purchaser of the

The guarantee is subject to proof of purchase being supplied.

This guarantee does not affect any statutory rights the consumer may have in law.

The guarantee covers manufacturing or material defects when installed in accordance with our instructions on specified tube materials and applications, and does not cover parts subject to normal wear and tear.

This product range has been designed for the use of homeowners, domestic and commercial applications and therefore the Guarantee is subject to the product being properly selected for their intended service conditions.

The guarantee is not applicable where the product is fitted contrary to the conditions in the fitting instructions.

This is reinforced where valves are covered by the European Pressure Equipment Directive (PED97/23/EC) where Installation, Operating and Maintenance Instructions are supplied with each product and/or carton.

Provided it is installed correctly and receives adequate preventative maintenance it should give years of trouble-

Abusive behaviour and accidental damage to the product are not covered by this guarantee.

The extent of this liability is limited to the cost of the replacement of the defective item and not to installation or consequential damages

APPROVALS





WRAS